

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 56/2026

Dated: 02/02/2026

It is certified that an inspection team headed by Dr. Muniswamy, CAS
 (Name of Officers with designation) from Medical Officer CHC-Panyam PHED

Inspected the Vijayanikethan High School

(Name & Address of the school) on 02/02/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. mjyADZQX dated 02/02/2026

Of Panyam (PHED Lab) certified that
 the Vijayanikethan High School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
 hygienic sanitation condition in the school building & the campus as per norms prescribed by
 the Central / State/ U.T.Govt.

This certificate is valid till One year

Signature with Seal Muniswamy

Name : Dr. Muniswamy

Designation : CAS - Anae

Name & Address of the Office/ Department:

MEDICAL OFFICER
 Community Health Center
 Directorate of Secondary Health
 Panyam-518112, Nandyal Dist. A.P

Vijayanikethan High School,
Panyam, Nandyal Dist.

(Name & Address of the institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/ Local bodies.

[Signature]
Manager
Vijayanikethan High School
 Panyam (M&M), Nandyal (Dist) - 518112.

[Signature]
Principal
Vijayanikethan High School
 Panyam (M&M), Nandyal (Dist) - 518112.

SANITARY CERTIFICATE

This is to certify that the building situated at D.No. 13-206/1, Panyam Village & Mandal, Nandyal District, Andhra Pradesh, belonging to **Vijayanikethan High School**, was inspected and found to be maintained in a neat and hygienic condition. The sanitary facilities, including toilets, bathrooms, urinals, and the drainage system available in the institution, are adequate to meet the needs of the occupants. The premises, buildings, and drinking water facilities are being maintained properly in a hygienic manner.



MEDICAL OFFICER
Community Health Centre
Directorate of Secondary Health
Panyam-518112, Nandyal Dist. A.P



Manager
Vijayanikethan High School
Panyam (Vi&M), Nandyal (Dist) -518 112.



Principal
Vijayanikethan High School
Panyam (Vi&M), Nandyal (Dist) -518 112.

GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY AND SANITATION
WATER QUALITY MONITORING LABORATORY -NANDYAL
REPORT ON CHEMICAL ANALYSIS OF WATER (DRINKING)

Received from: Vijayanikethan High School

Location: Vijayanikethan High School, Panyam (M), Nandyal (Dist), (Filter Water)

Date of Collection: 28/01/26

Date of Received: 28/01/26

Date of Issue: 30/01/26

			IS:10500-2012 Permissible Limits		
Sl. No	Characterstics	Measuring Units	Requirements (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Result
1	Colour	Hazens	5	15	Agreable
2	TURBIDITY	N.T.U	1	5	0.2
3	pH	Mg/L	6.5-8.5	No Relaxation	6.60
4	EC	μ/s	< 1000		120
5	T.D.S	Mg/L	500	2000	78
6	Total Alkalinity	Mg/L	200	600	24
7	Total Hardness (CaCO_3)	Mg/L	200	600	38
8	Calcium (as Ca^{++})	Mg/L	75	200	08
9	Magnesium (as Mg^{++})	Mg/L	30	100	05
10	Chlorides (as Cl^-)	Mg/L	250	1000	20
11	Flourides (as F^-)	Mg/L	1	1.5	0.04
12	Nitrate (as NO_3^-)	Mg/L	45	No Relaxation	02
13	Sulphate (as SO_4^{2-})	Mg/L	200	400	04
14	Iron (as Fe)	Mg/L	0.3	No Relaxation	0.03

Remarks :

The Above Water Sample is Physically and Chemically Satisfactory

Shreebh
Chemist
WQM Laboratory 30/1/26
NANDYAL

[Signature]
Manager
Vijayanikethan High School
Panyam (M&M), Nandyal (Dist) - P. : 112.

[Signature]
Principal
Vijayanikethan High School
Panyam (M&M), Nandyal (Dist) - P. : 112.

GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY AND SANITATION
WATER QUALITY MONITORING LABORATORY -NANDYAL
REPORT ON BACTERIOLOGICAL ANALYSIS OF WATER SAMPLE

Mandal :	Panyam		Village :	Panyam
Lab Reference No:	1		District:	NANDYAL
1	Sample received from		Vijayanikethan High School	
2	Sample collected by		Vijayanikethan High School	
3	Source of water		Filter Water	
4	Place Where collected		Vijayanikethan High School	
5	Date of collection		28/1/2026	
6	Date of received in laboratory		28/1/2026	
7	RC(Residual Chlorine) Value(PPM)		Nil	
	TEST	Reporting Results	Standards of Bacteriological Quality(as per Indian Standard Drinking Water Specification . IS 10500 :2012)	
* 1	MF (Membrane Filter Technique) Coliform/CFU/100ml	0	Should not contain > 0 For Treated Water	
** 2	E.Coli CFU/100ml.of water sample	0	Shall not be detectable in any 100 ml Sample(0)	

Remarks : BACTERIOLOGICAL SATISFACTORY

Date :30-1-2026

* E-Coli- Escherichia coli

K. Ravathi
Microbiologi- 30/01/2026
VQM Laboratory
NANDYAL


Manager
Vijayanikethan High School
Panyam (M&M), Nandyal (Dist) . 511 112.


Principal
Vijayanikethan High School
Panyam (M&M), Nandyal (Dist) . 511 112.