



**GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY AND SANITATION
WATER QUALITY MONITORING LABORATORY -NANDYAL
REPORT ON BACTERIOLOGICAL ANALYSIS OF WATER SAMPLE**

Mandal :	Panyam	Village :	Panyam
Lab Reference No:	1	District:	NANDYAL
1 *	Sample received from	Vijayanikethan High School	
2	Sample collected by	Vijayanikethan High School	
3	Source of water	Filter Water	
4	Place Where collected	Vijayanikethan High School	
5	Date of collection	28/1/2026	
6	Date of received in laboratory	28/1/2026	
7	RC(Residual Chlorine) Value(PPM)	Nil	
	TEST	Reporting Results	Standards of Bacteriological Quality(as per Indian Standard Drinking Water Specification . IS 10500 :2012)
* 1	MF (Membrane Filter Technique) Coliform/CFU/100ml	0	Should not contain > 0 For Treated Water
** 2	E.Coli CFU/100ml.of water sample	0	Shall not be detectable in any 100 ml Sample(0)

Remarks : BACTERIOLOGICAL SATISFACTORY

Date :30-1-2026

* E-Coli- Escherichia coli

K. Revathi
Microbiology
VQM Laboratory
NANDYAL
30/01/2026